



July 31, 2012

EVERGREEN CONCRETE PRODUCTS
RUSINS EVERGREEN ENTERPRISES INC.
RAND RUSIN
1681 N NORTH 2ND DR
STEVENS POINT WI 54482

Re: Description: SEWAGE TREATMENT APPARATUS, FILTER CONTAINER/VAULT
Manufacturer: EVERGREEN CONCRETE PRODUCTS
Product Name: FILTER BASIN
Model Number(s): FB1
[101+ GAL. CONCRETE FILTER BASIN; **TANK DIMENSIONS (OD) = 37 IN. L X 37 IN. W X 39.75 IN. H, TAPERED; 48 IN. MAX. DEPTH OF BURY**]
Product File No: 20120267

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2017.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use a department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The capacity of the sedimentation tank is exempt from the minimum capacity requirements of s. Comm 83.15 (3) of the Wis. Admin. Code. This tank capacity must not be included in the septic tank capacity required by s. Comm 83.15 (3) of the Wis. Admin. Code.
- A permanent warning label that conforms to s. SPS 384.25 (8), Wis. Adm. Code, must be attached to the cover of this product.
- The manhole cover shall be provided with a locking device that conforms to s. SPS 384.25 (7)(h) of the Wisconsin Administrative Code.
- **See Commerce approved effluent filters suitable for insertion:**
http://commerce.wi.gov/php/sb-ppalopp/manuf_result.php/988/ORENCO_SYSTEMS_INC#STAFVCV

This approval supersedes the approval issued on 6/25/2009 under product file number #20070140.

EVERGREEN CONCRETE PRODUCTS

Page 2

July 31, 2012

Product File No: 20120267

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20070140.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
DSPS WEST, Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
M-F 700-330
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV